



Office of the Chief Fire Officer
Pune Municipal Corporation

Out W.No : FB/ 3715

Date : 02/12/2022

To,
Gohad Architects,
Erandawane, Pune.

**Sub :-Final Fire NOC for the building of MAEER'S Vishwashanti Gurukul School at
S. No. 127 A(P), Kothrud,Pune.**
(For building height –14.75 Mtrs. & total Built up Area –8305.72 Sq.Mtrs only)

Ref :- i) Your Office letter Dt.07.11.2022.
ii) Provisional Fire Noc No. FB/1914,Dt.04.08.2018.
iii) Building Control Department,PMC No.CC/12859,Dt.16.02.2000.

Sir,

As per your request, visited the proposed site along with Mr. Mohan Jadhav on Dt.29.11.2022 and tested the Hydrant system, Hose Reel system with equipments and portable fire extinguishers suggested in Provisional Fire N.O.C. issued vide No. FB/1914,Dt.04.08.2018 issued by Fire Department.

The suggestions for fire protection arrangements as mentioned in the Provisional Fire N.O.C. are made by M/s. Sumeet Fire Engineers Pvt. Ltd., Pune "FORM A" to that effect is submitted to this office for the fire prevention, protection & fire fighting system installed in the above said building as per the Maharashtra Fire Prevention & Life Safety Measures Act 2006.

The fire fighting equipments and systems installed in the building should be maintained in high efficiency state and in proper working order at all time during the use of the building by owner or occupier. It will be your responsibility to get the yearly renewal of this Fire NOC after due inspection from the Fire Brigade authorities. The maintenance work of the fire fighting system shall be done by the licensed contractor, having license from Director, Maharashtra Fire services or Chief Fire Officer, Pune Fire Brigade. The list of the license contractor is available on [/www.maharashtrafireservices.org](http://www.maharashtrafireservices.org).

Name of the person, owner, responsible for the building maintenance should be informed to this office. Fire protection system provided in the building should not be removed from the building for any reason.

This Final No objection is subjected to any other conditions laid by any other department.

(Rajesh D. Jagtap)
Station Duty Officer
Pune Municipal Corporation

Copy to : Dy. Engineer (B.C.), PMC